

1543 - Bernie's Place

Retail Food - Retail Food

Physical Address:

1419 S 9TH ST Canon City, CO 81212

County: Fremont (22)

INSPECTION DATE:

05/14/2009

INSPECTION TYPE:

- REGULAR
- INTERVENTION
- FOLLOW-UP
- PRE-OPERATIONAL
- COMPLAINT

RED→CRITICAL ITEM VIOLATIONS are more likely than other violations to contribute to food contamination or illness. These violations involve the food source and condition, food cooking and storage temperatures, sanitizing utensils, water and sewage, handwashing and other sanitary practices, handwashing sinks and supplies, pest control and use of poisonous materials.

SANITIZATION RINSE

04c. In-place

- ↳ Corrective Action: Corrected On-Site. Correct-By: 05/14/2009
Inspector Comments: BAR-The beverage gun holder is dirty and moldy, partially full of sour liquid.

BLUE→NON-CRITICAL ITEM VIOLATIONS are not directly related to the cause of food-borne illness, but if uncorrected, could negatively affect the operation of the restaurant. These include a lack of facility cleanliness and poor maintenance of equipment and facilities.

UTENSILS, SINGLE-SERVICE ARTICLES

13b. Single-service articles stored, dispensed, used

- ↳ Inspector Comments: RESTROOMS-Paper towels not in holder or dispenser in both restrooms.

PHYSICAL FACILITIES

14a. Plumbing: installed, maintained

- ↳ Inspector Comments: BAR-The beverage gun holder does not drain properly.

14b. Garbage and refuse

↳

Inspector Comments: PREMISES-Old bags of twigs and leaves on the ground next to the cardboard recycle dumpster.



Inspector Comments: PREMISES-Dumpster is still not on a cement pad.

14d. Lighting



Inspector Comments: BAR-The bulbs in the recessed light fixtures and in the ceiling fan light fixtures are not shielded bulbs.

14e. Ventilation



Inspector Comments: KITCHEN-An approved make-up air system still has not been installed for the vent hood. Make-up air must be mechanical, must be equal to or greater than the volume of air exhausted by the vent hood and must be electrically interconnected to come on whenever the vent fan is turned on.

14g. Premises maintained



Inspector Comments: PREMISES-Broken furniture, unused items, stored behind the building.

ADDITIONAL COMMENTS:

1:45pm.

RECOMMENDED REGULATORY ACTION(S), RESOLUTION(S) & INTERVENTIONS:

CIVICS:

YES

NO

ON-SITE FOLLOW-UP:

YES

NO