

# 1586 - Canon City High School

## Schools - High School

Physical Address:

1313 COLLEGE AVE Canon City, CO 81212

County: Fremont (22)

INSPECTION DATE:

04/21/2009

INSPECTION TYPE:

- REGULAR
- FOLLOW-UP
- PRE-OPERATIONAL
- COMPLAINT

### SANITARY FACILITIES AND CONTROLS

03f. [Toilet, lavatory, bathing](#)

- ↳ Corrective Action: Corrected On-Site. Correct-By: 04/21/2009  
Inspector Comments: 3-606, Hot water is 128 Deg.F at the handsink in the Boy's Restroom in the Art Building. The maximum hot water temperature is 120 Deg.F. at any handsink or bathing facility.

### EQUIPMENT AND SUPPLIES

06a. [General](#)

- ↳ Inspector Comments: 6-106, The Head Custodian Storeroom door was open.

### LABS, INDUST, ARTS, VOCATIONAL

08a. [General](#)

- ↳ Inspector Comments: 8-101, Some of the equipment in the Welding Shop is not posted with operating instructions, regulations, procedures (for safely operating equipment). Equipment is typically posted with the yellow and black cards.
- ↳ Inspector Comments: 8-101, Some equipment in the Auto Shop is not posted with operating instructions, regulations and procedures.

08f. [Safety equipment](#)

- ↳ Inspector Comments: 8-119, Fire blankets are not provided in the science classrooms with gas jets.

08g. [Ventilation](#)

- ↳ Inspector Comments: 8-102, The kiln in the Art Classroom is not connected to the outside vent opening.
- ↳ Inspector Comments: 8-203,d., The ventilation hoods in the science classrooms are not air flow tested at least once a school year.

### HEALTH SERVICES

09a. [General](#)

- ↳ Inspector Comments: 9-104, Only 2 cots provided in the Health Services room, student enrollment of 1137 requires 3 cots (1 cot for each 400 students).
- ↳ Inspector Comments: 9-102, A list of all staff members that have a current American Red Cross Standard First Aid Course certification (or equivalent), is not kept at the school.

### MISCELLANEOUS

10c. [Radon monitored](#)

- ↳ Inspector Comments: 10-102, Radon test results are not available at the school; test results not available for the new addition (required within 19 months of occupancy of the new addition).

ADDITIONAL COMMENTS:

1:00pm.

CIVCS:

YES

NO

ON-SITE FOLLOW-UP:

YES

NO