

1588 - Lincoln Elementary

Schools - Elementary

Physical Address:
420 MYRTLE AVE Canon City, CO 81212
County: Fremont (22)

INSPECTION DATE:
09/15/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

SANITARY FACILITIES AND CONTROLS

03c. Refuse disposal



Inspector Comments: 3-303, Dumpster lids open.

03f. Toilet, lavatory, bathing



Inspector Comments: 3-608, Acoustical ceiling tiles in Kindergarten (#4) restrooms and sink area.



Inspector Comments: 3-606, After running for several minutes, hot water did not go above 71 Deg. F. at the restroom handsink in Kindergarten (#4) classroom. The hot water temperature at handsinks is required to be between 90-120 Deg.F.



Inspector Comments: 3-606, The hot water at the restroom handsinks in Kindergarten (#5 and #7) classrooms and 1st grade (#7 and #8) classrooms did not reach at least 90 Deg.F.



Inspector Comments: 3-608, Acoustical ceiling tiles in the restroom in the Nurse's Room.

FOOD SERVICE

07a. If applicable; see attached food service inspection



Inspector Comments: SPECIAL NEEDS CLASSROOM-7-102, No thermometer in the refrigerator

MISCELLANEOUS

10b. Asbestos plan



Inspector Comments: 10-101, The Asbestos Management Plan is not available at the school for review.

10c. Radon monitored



Inspector Comments: 10-102, Radon test results are not available at the school for review

ADDITIONAL COMMENTS:

9:55am.

CIVCS:

YES
 NO

ON-SITE FOLLOW-UP:

YES
 NO