

1589 - McKinley Elementary School

Child Care - Child Care Center

Physical Address:
1240 MCKINLEY AVE Canon City, CO 81212
County: Fremont (22)

INSPECTION DATE:
09/30/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

LICENSE STATUS
RECOMMENDATION
 APPROVED
 DENIED

RED→CRITICAL ITEM VIOLATIONS are more likely than other violations to contribute to illness or environmental hazards that may contribute to a disease outbreak. Critical item violations include inappropriate diapering procedures, lack of handwashing, ineffective sanitization and disinfection, ill personnel preparing food or caring for children, unsafe water supply or sewage disposal, vermin infestation, food temperature abuse and uncontrolled toxics.

PESTS/TOXICS

10b. Toxic Materials Control

- Corrective Action: Corrected On-Site. Correct-By: 09/30/2009
Inspector Comments: 10-204 The custodian's closet inside the Boy's Restroom is open and accessible.

BLUE→NON-CRITICAL ITEM VIOLATIONS are not directly related to the cause of illness, environmental hazards or disease outbreak, but if uncorrected, could negatively affect the operation of the child care facility. These include a lack of facility cleanliness and poor maintenance of equipment and facilities.

SANITARY FACILITIES & CONTROLS

04d. Plumbing

- Inspector Comments: 4-302 No hose-bib vacuum breaker installed on the mopsink faucet in the custodian's closet in the Boy's Restroom, section of hose attached to faucet. Install a hose-bib vacuum breaker on the faucet then you can re-install the quick-couple disconnect.

ADDITIONAL COMMENTS:
7:50am.

RECOMMENDED REGULATORY ACTION(S), RESOLUTION(S) & INTERVENTIONS:

CIVCS:

YES
 NO

ON-SITE FOLLOW-UP:

YES
 NO