



Colorado Department
of Public Health
and Environment

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT

4300 Cherry Creek Drive South

Denver, CO 80246-1530

Phone (303) 692-3620

Fax (303) 753-6809

Page 1 of 2

NAME OF SCHOOL WASHINGTON ELEMENTARY SCHOOL				SCHOOL DISTRICT FREMOUNT COUNTY SCHOOL DISTRICT RE-1				
PRINCIPAL JANICE ZEILER				PHONE NUMBER (719) 269-6280				
ADDRESS 606 N 9TH ST CANON CITY CO						ZIP 81212		
COUNTY	FIRM ID	INSPECTOR ID	DATE			TRAVEL TIME	INSPECT TIME	TYPE <input checked="" type="checkbox"/> REGULAR <input type="checkbox"/> FOLLOW-UP <input type="checkbox"/> PRE-OPERATIONAL <input type="checkbox"/> COMPLAINT
			MONTH	DAY	YEAR			
22	1591	259	10	26	10	2	60	

SCHOOL INSPECTION REPORT

Items circled below identify violations to be corrected as indicated by the regulatory authority. Failure to comply may result in further action by the regulatory authority.

2.0. GROUNDS

- a. General

3.0. SANITARY FACILITIES AND CONTROLS

- a. Water
 b. Sewage disposal
 c. Refuse disposal
 d. Insects, rodents, animals
 e. Plumbing
 f. Toilet, lavatory, bathing
 g. Swimming pool (if applicable; see attached pool inspection)

4.0. BUILDING, OCCUPANCY, SPACE AND USE

- a. General

5.0. MECHANICAL

- a. Electrical
 b. Lighting
 c. Ventilation
 d. Heating

6.0. EQUIPMENT AND SUPPLIES

- a. General

7.0. FOOD SERVICE

- a. If applicable; see attached food service inspection
 b. Dining area

8.0. LABS, INDUST, ARTS, VOCATIONAL

- a. General
 b. Chemical storage, handling
 c. Chemical inventory
 d. MSDS
 e. Written plans
 f. Safety equipment
 g. Ventilation

9.0. HEALTH SERVICES

- a. General

10.0. MISCELLANEOUS

- a. General
 b. Asbestos plan
 c. Radon monitored

259

ENVIRONMENTAL HEALTH SPECIALIST

ID#

RECEIVED BY

TITLE

Colorado Department of Public Health and Environment

Schools Inspection Report

Items described below identify violations to be corrected as indicated by the regulatory authority. Failure to comply may result in further action by the regulatory authority.

Name of School Washington Elementary School	City Canon City	Firm ID 1591	Date (mm/dd/yy) 10/26/2010
---	---------------------------	------------------------	--------------------------------------

Item #	Remarks	Method of/for Correction	Corrected by (MM/DD/YY)
03 f	Hot water at sinks accessible by the students exceeds the maximum temperature of 120 Deg.F at several handsinks; 139 Deg.F in the nurse's restroom, 132 Deg.F at handsinks in the Modular Classrooms, 131 Deg.F in Kindergarten classroom #35 and #36, 132 Deg.F in Kindergarten classroom #38		
03 f	3-608, Several restrooms still have accoustical ceiling tiles. As resources allow and when repairs are required in restrooms, replace accoustical ceiling finishes with smooth and washable ceilings.		
06 a	6-103, No sanitizer for the body contact mats used in gym classes. Clean and sanitize body contact surfaces when the mats are used.		
08 b	A written plan explaining the proper storage, handling and disposal procedures for all poisonous, toxic or hazardous substances was not in the procedures manuals provided.		
08 e	A list of first aid procedures and a phone number for accidental poisoning not posted.		
08 e	A written plan for response to and cleanup of chemical spills was not in the procedures manuals provided.		
09 a	9-104 The vinyl cover on one of the cots in the nurse's office is torn.		
09 a	A current list of all staff members with a current American Red Cross Standard First Aid Course or equivalent is not available. If staff members other than the school nurse have the necessary certification, a complete list is required to be kept on file.		
10 b	No asbestos management plan complying with the provisions of the Colorado Air Quality Control Commission Regulation No. 8 is on file or available for review.		
10 c	Radon test results not available for review.		
Comments			
Environmental Health Specialist:		Received by:	

Method of/for Correction
 Corrected On Site (COS):
 CIVCS:
 Follow-Up (F/U):
 Compliance Agreement (CA):