

1599 - Fremont County Headstart

Child Care - Headstart

Physical Address:
1718 BROOKSIDE Canon City, CO 81212
County: Fremont (22)

INSPECTION DATE:
09/24/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

LICENSE STATUS
RECOMMENDATION
 APPROVED
 DENIED

RED→CRITICAL ITEM VIOLATIONS are more likely than other violations to contribute to illness or environmental hazards that may contribute to a disease outbreak. Critical item violations include inappropriate diapering procedures, lack of handwashing, ineffective sanitization and disinfection, ill personnel preparing food or caring for children, unsafe water supply or sewage disposal, vermin infestation, food temperature abuse and uncontrolled toxics.

BLUE→NON-CRITICAL ITEM VIOLATIONS are not directly related to the cause of illness, environmental hazards or disease outbreak, but if uncorrected, could negatively affect the operation of the child care facility. These include a lack of facility cleanliness and poor maintenance of equipment and facilities.

SANITARY FACILITIES & CONTROLS

04b. Water Accessibility



Inspector Comments: 4-104(b) Hot water is 80 Deg.F from the hands-free faucet in the Men's Restroom in Building #3, The minimum temperature is 90 Deg.F (90-120).



Inspector Comments: 4-104(b) Hot water is 121 Deg.F at the regular faucet in Unit B, Building #2. Hot water is 125 Deg.F at the regular faucet in the Polar Bear classroom, Building #6.

04e. Toilet Facilities



Inspector Comments: 4-401 The painted finish is worn through on the toilet seat in the Boy's Bathroom, Unit C, Building #4.

ADDITIONAL COMMENTS:
9:55am.

RECOMMENDED REGULATORY ACTION(S), RESOLUTION(S) & INTERVENTIONS:

CIVCS:
 YES
 NO

ON-SITE FOLLOW-UP:
 YES
 NO