

4775 - Saint Michael's Pre-School

Child Care - Preschool

Physical Address:
1016 MYSTIC Canon City, CO 81212
County: Fremont (22)

INSPECTION DATE:
04/27/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

LICENSE STATUS
RECOMMENDATION
 APPROVED
 DENIED

RED→CRITICAL ITEM VIOLATIONS are more likely than other violations to contribute to illness or environmental hazards that may contribute to a disease outbreak. Critical item violations include inappropriate diapering procedures, lack of handwashing, ineffective sanitization and disinfection, ill personnel preparing food or caring for children, unsafe water supply or sewage disposal, vermin infestation, food temperature abuse and uncontrolled toxics.

BLUE→NON-CRITICAL ITEM VIOLATIONS are not directly related to the cause of illness, environmental hazards or disease outbreak, but if uncorrected, could negatively affect the operation of the child care facility. These include a lack of facility cleanliness and poor maintenance of equipment and facilities.

SANITARY FACILITIES & CONTROLS

04b. Water Accessibility



Inspector Comments: 4-104(b), Hot water at the restroom handsinks and at the classroom handsinks is only 66 Deg.F. after running for several minutes. The minimum hot water temperature is 90 Deg.F (90 Deg.F.-120 Deg.F. maximum).

FOOD SERVICE

07b. Equipment Design



Inspector Comments: 7-101(d), Thermometer missing or not visible in the refrigerator.

ADDITIONAL COMMENTS:
10:15am.

CIVCS:
 YES
 NO

ON-SITE FOLLOW-UP:
 YES
 NO