

9288 - Mountain View Core Knowledge School

Schools - Elementary

Physical Address:
890 Field Canon City, CO 81212
County: Fremont (22)

INSPECTION DATE:
09/30/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

SANITARY FACILITIES AND CONTROLS

03e. [Plumbing](#)



Inspector Comments: 3-609 No keyed hose bib in the Women's Restroom next to the gym. The Men's Restroom also does not have a keyed hose bib, but there is a custodian's closet with a mopsink which could be used to hose the floor if necessary.

LABS, INDUST, ARTS, VOCATIONAL

08c. [Chemical inventory](#)



Inspector Comments: Chemicals, solvents and hazardous substances are not inventoried each year, including the name, amount, and date it entered the school. This would include maintenance and cleaning supplies as well as the chemicals in the Science Classroom.

08e. [Written plans](#)



Inspector Comments: 8-113 A written plan that explains the proper storage, handling and disposal procedures for all poisonous, toxic or hazardous substances is not available. GUIDELINES FOR THE DEVELOPMENT OF A CHEMICAL HYGIENE PLAN from CDPHE (State Health) are on file but no written plan.

MISCELLANEOUS

10c. [Radon monitored](#)



Inspector Comments: 10-102 Radon test results not available for review.

ADDITIONAL COMMENTS:

CIVCS:
 YES
 NO

ON-SITE FOLLOW-UP:
 YES
 NO