

9633 - Kinderhaus

Child Care - Child Care Center

Physical Address:
810 E 3rd ST Florence, CO 81226
County: Fremont (22)

INSPECTION DATE:
07/30/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

LICENSE STATUS
RECOMMENDATION
 APPROVED
 DENIED

RED→CRITICAL ITEM VIOLATIONS are more likely than other violations to contribute to illness or environmental hazards that may contribute to a disease outbreak. Critical item violations include inappropriate diapering procedures, lack of handwashing, ineffective sanitization and disinfection, ill personnel preparing food or caring for children, unsafe water supply or sewage disposal, vermin infestation, food temperature abuse and uncontrolled toxics.

PESTS/TOXICS

10b. Toxic Materials Control

- ↳ Corrective Action: Corrected On-Site. Correct-By: 07/30/2009
Inspector Comments: 10-204 The door to the "Women's Restroom" (used as a storage room) is unlocked, paint, detergent and other items are stored in this room.

BLUE→NON-CRITICAL ITEM VIOLATIONS are not directly related to the cause of illness, environmental hazards or disease outbreak, but if uncorrected, could negatively affect the operation of the child care facility. These include a lack of facility cleanliness and poor maintenance of equipment and facilities.

PREMISES

02a. General

- ↳ Inspector Comments: 2-103 The dumpster lids are open, 1 dumpster lid is damaged.
- ↳ Inspector Comments: 2-101 Some pieces of unused equipment stored outside on the north side of the building.

BUILDING

03c. Finishes

- ↳ Inspector Comments: 3-103 (h) Carpet on the floor under the handsink in the Toddler's Room. At the first opportunity, replace the carpet with an approved floor covering just in the sink area.

DISEASE PREVENTION

06k. Sanitizer/Disinfectant Test/Store

- ↳ Inspector Comments: 6-406(b) In the Infant Room, disinfectant is labeled "Bleach Water" only and not labeled for intended use. Make sure all spray bottles of sanitizer and disinfectant are labeled as to content and their intended use, such as sanitizer/toys and tables, disinfectant/restrooms and diaper tables.
- ↳ Inspector Comments: 6-405 No disinfectant test papers to check concentration of bleach water used as disinfectant (500-1000 ppm).

Inspector Comments: 6-406 No quaternary ammonium test papers to test the concentration of the ALTIMA 64M used as a sanitizer in the Infant Room. Up to 400 ppm is the allowable concentration for a quat used as a sanitizer.

FOOD SERVICE

07b. Equipment Design



Inspector Comments: 7-101 The top surface and the edges of the KITCHEN island are damaged, edge trim is missing.

ADDITIONAL COMMENTS:
10:05am.

RECOMMENDED REGULATORY ACTION(S), RESOLUTION(S) & INTERVENTIONS:

CIVCS: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	ON-SITE FOLLOW-UP: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
---	---