

10314 - Ohana House

Child Care - Specialize Group

Physical Address:
431 Harrison Canon City, CO 81212
County: Fremont (22)

INSPECTION DATE:
09/23/2009

INSPECTION TYPE:
 REGULAR
 FOLLOW-UP
 PRE-OPERATIONAL
 COMPLAINT

LICENSE STATUS
RECOMMENDATION
 APPROVED
 DENIED

RED→CRITICAL ITEM VIOLATIONS are more likely than other violations to contribute to illness or environmental hazards that may contribute to a disease outbreak. Critical item violations include inappropriate diapering procedures, lack of handwashing, ineffective sanitization and disinfection, ill personnel preparing food or caring for children, unsafe water supply or sewage disposal, vermin infestation, food temperature abuse and uncontrolled toxics.

BLUE→NON-CRITICAL ITEM VIOLATIONS are not directly related to the cause of illness, environmental hazards or disease outbreak, but if uncorrected, could negatively affect the operation of the child care facility. These include a lack of facility cleanliness and poor maintenance of equipment and facilities.

BUILDING

03a. Clean/Good Repair



Inspector Comments: 3-101 Some dead insects observed in the building. A licensed pest control company is providing services to this facility, and the problem appears to be under adequate control at this time.

SANITARY FACILITIES & CONTROLS

04b. Water Accessibility



Inspector Comments: 4-104(b) No hot water to the handsink in the upstairs bathroom. The pilot light to the water heater supplying water to this bathroom and the shower next door, may be out.



Inspector Comments: 4-104(c) No hot water to the upstairs shower.

04e. Toilet Facilities



Inspector Comments: 4-407 No vent fan in the basement shower room.



Inspector Comments: 4-405 Toilet paper dispenser is empty in the basement toilet room.

04f. Handwashing/Bathing Facilities



Inspector Comments: 4-503(a) Soap and paper towels missing in some restrooms.



Inspector Comments: 4-503(a) No paper towels at the kitchen handsink.

DISEASE PREVENTION

06k. Sanitizer/Disinfectant Test/Store



Inspector Comments: 6-405 No test papers to check concentration of bleach water used as sanitizer and as disinfectant.

FOOD SERVICE

07b. Equipment Design



Inspector Comments: 7-101 The long cabinet in the kitchen is not sealed to the floor.



Inspector Comments: 7-101 No thermometer in the kitchen refrigerator.



Inspector Comments: 7-101 No metal-stem food thermometer for use in the kitchen.



Inspector Comments: 7-101(e) The existing domestic dishmachine is no longer working. If you purchase a new domestic dishmachine, the machine must meet the following requirements: dishmachine must be equipped with a heat sanitizing cycle which reaches a minimum of 150 Deg.F, or the water temperature in a dishmachine without a sanitizing cycle must reach a minimum of 155 Deg.F.

ADDITIONAL COMMENTS:

RECOMMENDED REGULATORY ACTION(S), RESOLUTION(S) & INTERVENTIONS:
--

CIVCS: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	ON-SITE FOLLOW-UP: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
---	---