

# 10508 - HARRISON SCHOOL

## Schools - Middle School

Physical Address:  
920 FIELD AVE CANON CITY, CO 81212  
County: Fremont (22)

INSPECTION DATE: 11/03/2009

### INSPECTION TYPE:

- REGULAR  
 FOLLOW-UP  
 PRE-OPERATIONAL  
 COMPLAINT

### SANITARY FACILITIES AND CONTROLS

03f. Toilet, lavatory, bathing



Inspector Comments: 3-608 Acoustical ceiling tiles in the restroom in the Health Room A134. When the acoustical ceiling tiles need to be replaced, replace with smooth, washable tiles.

### MECHANICAL

05c. Ventilation



Inspector Comments: 5-301 Occasional odors in the NE wing (art classrooms). The major problem from 2007 has been corrected.

### LABS, INDUST, ARTS, VOCATIONAL

08f. Safety equipment



Inspector Comments: 8-101 The bandsaw and drill press in the Shop Room (A224) are not posted with operating instructions, regulations and procedures.



Inspector Comments: 8-118 Only 1 pair of safety glasses in the cabinet in the Shop Room A224). Make sure there are an adequate number of pairs of safety glasses and that the safety glasses are cleaned and sanitized between uses.

### ADDITIONAL COMMENTS:

9:00am, 1:30pm.  
Enrollment 725

Asbestos Plan Date August 3, 2006  
Radon Monitored Date December 3, 2006

### CIVCS:

- YES  
 NO

### ON-SITE FOLLOW-UP:

- YES  
 NO