

# 10656 - Florence High School

## Schools - High School

Physical Address:

2006 State Hwy 67 FLORENCE, CO 81226

County: Fremont (22)

INSPECTION DATE:

01/28/2009

INSPECTION TYPE:

- REGULAR  
 FOLLOW-UP  
 PRE-OPERATIONAL  
 COMPLAINT

### LABS, INDUST, ARTS, VOCATIONAL

08a. [General](#)



Inspector Comments: 8-101 Equipment in the Applied Tech classroom (C108) not posted with operating instructions, regulations and procedures.



Inspector Comments: 8-101 In Welding Shop and Wood Shop, equipment not posted with operating instructions, regulations and procedures.

08b. [Chemical storage, handling](#)



Inspector Comments: 8-113 A written plan explaining proper storage, handling and disposal procedures for all poisonous, toxic or hazardous substances is not available and kept in a location away from where these substances are stored.

08c. [Chemical inventory](#)



Inspector Comments: 8-108 Chemical inventory in the Science Lab Storeroom is not kept updated. Note-Inventory requirement applies to all chemicals including cleaning and maintenance chemicals.

08e. [Written plans](#)



Inspector Comments: 8-112 A written plan for response to and cleanup of chemical spills not provided for chemicals in the Science Labs. Note-Written plan applies to all chemicals including cleaning and maintenance chemicals.

08f. [Safety equipment](#)



Inspector Comments: 8-119 The fire blanket is not mounted on the wall in the Science Lab and no fire blanket provided in the Bio Science Lab.



Inspector Comments: 8-123 A key for the Master Electrical shut-off switches is not available in the Science Labs.

08g. [Ventilation](#)



Inspector Comments: 8-203 Vent hoods in Science labs are not air flow tested annually.

### MISCELLANEOUS

10c. [Radon monitored](#)



Inspector Comments: 10-102 Radon test results not available. Note-Radon testing and re-testing for the entire district will be done this school year.

ADDITIONAL COMMENTS:

1:05pm.

CIVCS:

YES

NO

ON-SITE FOLLOW-UP:

YES

NO