



Colorado Department
of Public Health
and Environment

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT

4300 Cherry Creek Drive South

Denver, CO 80246-1530

Phone (303) 692-3620

Fax (303) 753-6809

Page 1 of 2

NAME OF SCHOOL FREMONT MIDDLE SCHOOL				SCHOOL DISTRICT FREMONT SCHOOL DISTRICT RE-2				
PRINCIPAL NICK CAROCHI				PHONE NUMBER (719) 784-4856				
ADDRESS 215 N MAPLE FLORENCE CO						ZIP 81226		
COUNTY	FIRM ID	INSPECTOR ID	DATE			TRAVEL TIME	INSPECT TIME	TYPE <input checked="" type="checkbox"/> REGULAR <input type="checkbox"/> FOLLOW-UP <input type="checkbox"/> PRE-OPERATIONAL <input type="checkbox"/> COMPLAINT
22	10697	259	MONTH	DAY	YEAR	20	150	
			04	15	10			

SCHOOL INSPECTION REPORT

Items circled below identify violations to be corrected as indicated by the regulatory authority. Failure to comply may result in further action by the regulatory authority.

2.0. GROUNDS

a. General

3.0. SANITARY FACILITIES AND CONTROLS

- a. Water
- b. Sewage disposal
- c. Refuse disposal
- d. Insects, rodents, animals
- e. Plumbing
- f. Toilet, lavatory, bathing
- g. Swimming pool (if applicable; see attached pool inspection)

4.0. BUILDING, OCCUPANCY, SPACE AND USE

a. General

5.0. MECHANICAL

- a. Electrical
- b. Lighting
- c. Ventilation
- d. Heating

6.0. EQUIPMENT AND SUPPLIES

a. General

7.0. FOOD SERVICE

- a. If applicable; see attached food service inspection
- b. Dining area

8.0. LABS, INDUST, ARTS, VOCATIONAL

- a. General
- b. Chemical storage, handling
- c. Chemical inventory
- d. MSDS
- e. Written plans
- f. Safety equipment
- g. Ventilation

9.0. HEALTH SERVICES

a. General

10.0. MISCELLANEOUS

- a. General
- b. Asbestos plan
Date 10/21/2008
- c. Radon monitored
Date 06/15/2009

259

ENVIRONMENTAL HEALTH SPECIALIST

ID#

RECEIVED BY

TITLE

Colorado Department of Public Health and Environment

Schools Inspection Report

Items described below identify violations to be corrected as indicated by the regulatory authority. Failure to comply may result in further action by the regulatory authority.

Name of School Fremont Middle School	City FLORENCE	Firm ID 10697	Date (mm/dd/yy) 04/15/2010
--	-------------------------	-------------------------	--------------------------------------

Item #	Remarks	Method of/for Correction	Corrected by (MM/DD/YY)
03 e	3-606 In the T&I Building, hot water is 137 Deg.F at the restroom handsinks, the maximum water temperature is 120 Deg.F.		
03 f	3-608 In the T&I Building, Nurse's Office, the restroom has an acoustical ceiling (not smooth and washable).		
08 a	8-101 In the T&I Building, Home Bi Ed shop, power equipment is not posted with operating instructions, regulations and procedures.		
08 b	8-113 A written plan that explains the proper storage, handling and disposal procedures for all poisonous, toxic or hazardous substances was not available for review. This written plan is required to be on file in each school, in a location away from the areas where these substances are stored, and available for review upon request. This written plan would apply to substances stored and used in science classrooms, science storerooms, as well as maintenance and cleaning chemicals used throughout the facility.		
08 e	8-112 A written plan for response to and cleanup of chemical spills was not available for review. A copy of the plan shall be kept on file in a location away from the areas where chemicals are stored. This written plan would apply to chemicals stored and used in science classrooms, science storerooms, as well as maintenance and cleaning chemicals used throughout the facility.		
09 a	9-102 The school currently has 1 or more staff members with a current certification from the American Red Cross Standard First Aid Course or equivalent, but a list of staff members with certification is not available at the school, the list is kept at Florence High School.		
Comments	9:00am. Current enrollment is 430 students.		
Environmental Health Specialist:		Received by:	

Method of/for Correction

Corrected On Site (COS): CIVCS: Follow-Up (F/U): Compliance Agreement (CA):