

# 7923 - 4 Mile Adventist Christian School

## Schools - Elementary

Physical Address:  
3180 E Main Canon City, CO 81212  
County: Fremont (22)

INSPECTION DATE:  
01/12/2009

INSPECTION TYPE:  
 REGULAR  
 FOLLOW-UP  
 PRE-OPERATIONAL  
 COMPLAINT

### SANITARY FACILITIES AND CONTROLS

03f. [Toilet, lavatory, bathing](#)



Inspector Comments: (3-606) Hot water exceeds 120 Deg.F at handsinks, water was 157 Deg.F at time of inspection.

### FOOD SERVICE

07a. [If applicable; see attached food service inspection](#)



Inspector Comments: (7-102) No thermometer in the new refrigerator.

### LABS, INDUST, ARTS, VOCATIONAL

08b. [Chemical storage, handling](#)



Inspector Comments: (8-113) No written plan for the proper storage, handling and disposal procedures for all poisonous, toxic or hazardous substances.

08d. [MSDS](#)



Inspector Comments: (8-109) No MSDS for poisonous, toxic or hazardous substances.

08e. [Written plans](#)



Inspector Comments: (8-112) No written plan for response to and cleanup of chemical spills.

### MISCELLANEOUS

10c. [Radon monitored](#)



Inspector Comments: (10-102) Results of radon testing could not be located, radon testing has been done according to the principal.

ADDITIONAL COMMENTS:  
4:00pm.

#### CIVCS:

YES  
 NO

#### ON-SITE FOLLOW-UP:

YES  
 NO